

Energy performance certificate (EPC)

Unit 17
Finnimore Industrial Estate
Ottery St Mary
EX11 1NR

Energy rating

D

Valid until: **1 June 2033**

Certificate number: **6042-3637-1692-6475-6902**

Property type

Retail/Financial and Professional Services

Total floor area

333 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built	12 A
If typical of the existing stock	49 B

Breakdown of this property’s energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	34.9
Primary energy use (kWh/m2 per year)	250

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/6626-7651-9449-0603-4723\)](/energy-certificate/6626-7651-9449-0603-4723).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Zak Henning
Telephone	01392 435 052
Email	zak@energyperformancedirect.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID201039
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Employer	Energy Performance Direct
Employer address	PO Box 686, Exeter, EX1 9PD
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	30 May 2023
Date of certificate	2 June 2023
